



Test Report: ES-SU6K

6000VA On line UPS

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Control Function Test

Component Stress Test

■ E.M.C. TEST

E.M.C. Test

■ RELIABILITY TEST

ENVIRONMENT TEST

■ DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	OUTPUT VOLTAGE TOLERANCE	V: -1% ~ +1%	I/P: Line mode bat mode O/P: 220VAC for Line mode 220VAC for bat mode 230VAC for Line mode 230VAC for bat mode 240VAC for Line mode 240VAC for bat mode FULL~ MIN. LOAD Ta:25°C	output 230V: Line mode: No load: 229.3V Full load: 228.8V Bat mode: No load: 229.3V Full load: 228.8V Output 220V: Line mode: No load: 219.3V Full load: 218.6V Bat mode: No load: 219.3V Full load: 218.8V Output 240V: Line mode: No load: 239.3V Full load: 238.8V Bat mode: No load: 239.2V Full load: 238.7V
2	FREQUENCY (BAT MODE)	50Hz±0.1Hz for 50HZ 60Hz±0.1Hz for 60HZ	I/P: bat mode O/P: 230VAC 50HZ/60HZ for FULL LOAD Ta:25°C	50.0HZ @50Hz setting 60.0HZ @60Hz setting
3	FREQUENCY (ONLINE MODE SYNC RANGE FOR NORMAL OPERATION)	50Hz±4Hz for 50HZ 60Hz±4Hz for 60HZ	I/P: 230VAC 50±4HZ 240VAC 60±4HZ O/P: Min load Ta:25°C	50.0HZ@50Hz setting 60.0HZ@60Hz setting
4	FREQUENCY (ON LINE MODE FOR FREQUENCY CONVERTER OPERATION)	50Hz±0.1Hz for 50HZ 60Hz±0.1Hz for 60HZ	I/P: 230VAC 46~54HZ 240VAC 56~64HZ O/P: 230VAC50HZ/60HZfor FULL LOAD Ta:25°C	50.0 Hz @50Hz setting 60.0 Hz @60Hz setting

5	THD	1% @ full linear load 4% @ Non linear load	I/P: 230VAC 50HZ O/P: 230VAC 50HZ for FULL LOAD	Oline Mode: 0.757 % @ full linear load 1.798% @ Non linear load Bat Mode: 0.813% @ full linear load 2.263% @ Non linear load
6	LOAD CAPABILITY	105% <Load ≤ 125% transfer to bypass after 10 min (+/- 4s); 125% < Load ≤ 150% Warning, transfer to bypass mode after 60s (+/- 4s); 150% <Load immediately	I/P: 230VAC 50HZ O/P: Ta:25°C	600.35s @110.8% load 60.34s @135.1% load 0.51s @153.0% load
7	EFFICIENCY	95% online model 92% bat model	I/P: 230VAC 50HZ 240VAC 60HZ O/P: Full load Ta:25°C	online model: 95.3%@230VAC 50HZ 93.3%@240VAC 60HZ bat model: 95.5%@230VAC 50HZ 93%@240VAC 60HZ
8	TRANSFER TIME	0S online model 0S bat model	I/P: 230VAC 50HZ 240VAC 60HZ O/P: Full load Ta:25°C	ac to bat: 0ms@230VAC 50HZ 0ms@240VAC 60HZ bat to ac: 0ms@230VAC 50HZ 0ms@240VAC 60HZ

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	INPUT VOLTAGE RANGE	110VAC~300VAC	I/P: TESTING O/P: FULL / 60% LOAD Ta:25°C	176V~300V/ FULL LOAD 110V~176V/ 60% LOAD
				TEST : PASS
2	INPUT FREQUENCY RANGE	46HZ ~54HZ@seting 50HZ 56HZ~64 HZ@seting 60HZ 40HZ~70HZ@seting 发电机 NO DAMAGE	I/P:110VAC ~300VAC O/P:FULL~MIN LOAD Ta:25°C	TEST : PASS
3	POWER FACTOR	≥0.99	I/P: 208VAV 220VAC 230 VAC 240VAC O/P:FULL LOAD Ta:25°C	0.996@208VAV 0.997@220VAC 0.997@230 VAC 0.997@240VAC

4	THDI	≤4%	I/P: 208VAV 220VAC 230 VAC 240VAC O/P:FULL LOAD Ta:25°C	3%@208VAV 3%@220VAC 3%@230 VAC 3%@240VAC
---	------	-----	---	---

■ E.M.C. TEST

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	HARMONIC	BS EN/EN61000-3-12 CLASS A	I/P:230VAC/50HZ O/P:FULL LOAD Ta:25°C	PASS
2	CONDUCTION	BS EN/IEC 62040-32 CLASS B	I/P : 230 VAC (50HZ) O/P : FULL/50% LOAD Ta : 25°C	PASS Test by certified Lab
3	RADIATION	BS EN/IEC 62040-32 CLASS B	I/P : 230 VAC (50HZ) O/P : FULL LOAD Ta : 25°C	PASS Test by certified Lab
4	E.S.D	BS EN/EN61000-4-2 INDUSTRY AIR : 4KV / Contact : 4KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
5	E.F.T	BS EN/EN61000-4-4 INDUSTRY INPUT : 1KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
6	SURGE	BS EN/EN61000-4-5 INDUSTRY Line-Line : 1KV Line-Line-Chassis : 2KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
7	Test by certified Lab & Test Report Prepare Any contradictions of the test results, please refer to the latest EMC test report			

■ RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																																																																																				
1	TEMPERATURE RISE TEST	MODEL : ES-SU6K 1.HIGH AMBIENT BURN-IN : 2 HRS I/P : 198VAC/60HZ O/P : FULL LOAD 240V BATTERY Ta= 40°C 2.HIGH AMBIENT BURN-IN : 2 HRS I/P : 264VAC/50HZ O/P : FULL LOAD 240V BATTERY Ta= 40°C <table><tr><th>NO</th><th>Position</th><th>198VAC/60HZ</th><th>264VAC/50HZ</th></tr><tr><td>1</td><td>C5</td><td>47.0°C</td><td>46.5°C</td></tr><tr><td>2</td><td>C17</td><td>71.8°C</td><td>56.8°C</td></tr><tr><td>3</td><td>TX12</td><td>69.5°C</td><td>63.9°C</td></tr><tr><td>4</td><td>L5</td><td>101.4°C</td><td>98.6°C</td></tr><tr><td>5</td><td>RY4</td><td>71.0°C</td><td>60.3°C</td></tr><tr><td>6</td><td>L1</td><td>92.2°C</td><td>68.3°C</td></tr><tr><td>7</td><td>C13</td><td>64.2°C</td><td>55.0°C</td></tr><tr><td>8</td><td>C101</td><td>58.0°C</td><td>50.2°C</td></tr><tr><td>9</td><td>L3</td><td>85.7°C</td><td>63.4°C</td></tr><tr><td>10</td><td>L4</td><td>67.0°C</td><td>54.2°C</td></tr><tr><td>11</td><td>TX3</td><td>60.5°C</td><td>55.0°C</td></tr><tr><td>12</td><td>TX11</td><td>54.4°C</td><td>50.1°C</td></tr><tr><td>13</td><td>RY10</td><td>44.6°C</td><td>42.4°C</td></tr><tr><td>14</td><td>RY8</td><td>45.8°C</td><td>43.1°C</td></tr><tr><td>15</td><td>TX8</td><td>41.1°C</td><td>40.8°C</td></tr><tr><td>16</td><td>C4</td><td>48.9°C</td><td>46.3°C</td></tr><tr><td>17</td><td>L7</td><td>65.2°C</td><td>68.3°C</td></tr><tr><td>18</td><td>CT1</td><td>64.3°C</td><td>63.7°C</td></tr><tr><td>19</td><td>L9</td><td>56.2°C</td><td>55.7°C</td></tr><tr><td>20</td><td>TX3</td><td>55.6°C</td><td>55.1°C</td></tr><tr><td>21</td><td>L6</td><td>53.7°C</td><td>57.0°C</td></tr><tr><td>22</td><td>TX7</td><td>46.4°C</td><td>46.3°C</td></tr><tr><td>23</td><td>U3</td><td>46.9°C</td><td>45.5°C</td></tr><tr><td>24</td><td>U10</td><td>50.7°C</td><td>48.8°C</td></tr></table>			NO	Position	198VAC/60HZ	264VAC/50HZ	1	C5	47.0°C	46.5°C	2	C17	71.8°C	56.8°C	3	TX12	69.5°C	63.9°C	4	L5	101.4°C	98.6°C	5	RY4	71.0°C	60.3°C	6	L1	92.2°C	68.3°C	7	C13	64.2°C	55.0°C	8	C101	58.0°C	50.2°C	9	L3	85.7°C	63.4°C	10	L4	67.0°C	54.2°C	11	TX3	60.5°C	55.0°C	12	TX11	54.4°C	50.1°C	13	RY10	44.6°C	42.4°C	14	RY8	45.8°C	43.1°C	15	TX8	41.1°C	40.8°C	16	C4	48.9°C	46.3°C	17	L7	65.2°C	68.3°C	18	CT1	64.3°C	63.7°C	19	L9	56.2°C	55.7°C	20	TX3	55.6°C	55.1°C	21	L6	53.7°C	57.0°C	22	TX7	46.4°C	46.3°C	23	U3	46.9°C	45.5°C	24	U10	50.7°C	48.8°C
NO	Position	198VAC/60HZ	264VAC/50HZ																																																																																																					
1	C5	47.0°C	46.5°C																																																																																																					
2	C17	71.8°C	56.8°C																																																																																																					
3	TX12	69.5°C	63.9°C																																																																																																					
4	L5	101.4°C	98.6°C																																																																																																					
5	RY4	71.0°C	60.3°C																																																																																																					
6	L1	92.2°C	68.3°C																																																																																																					
7	C13	64.2°C	55.0°C																																																																																																					
8	C101	58.0°C	50.2°C																																																																																																					
9	L3	85.7°C	63.4°C																																																																																																					
10	L4	67.0°C	54.2°C																																																																																																					
11	TX3	60.5°C	55.0°C																																																																																																					
12	TX11	54.4°C	50.1°C																																																																																																					
13	RY10	44.6°C	42.4°C																																																																																																					
14	RY8	45.8°C	43.1°C																																																																																																					
15	TX8	41.1°C	40.8°C																																																																																																					
16	C4	48.9°C	46.3°C																																																																																																					
17	L7	65.2°C	68.3°C																																																																																																					
18	CT1	64.3°C	63.7°C																																																																																																					
19	L9	56.2°C	55.7°C																																																																																																					
20	TX3	55.6°C	55.1°C																																																																																																					
21	L6	53.7°C	57.0°C																																																																																																					
22	TX7	46.4°C	46.3°C																																																																																																					
23	U3	46.9°C	45.5°C																																																																																																					
24	U10	50.7°C	48.8°C																																																																																																					
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 264VAC/100VAC O/P : 100% LOAD Ta= 0 °C	TEST : OK																																																																																																				
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 40°C/95 %R.H NO DAMAGE	I/P : 300VAC O/P : FULL LOAD Ta= 40 °C HUMIDITY= 95 %R.H	TEST : OK																																																																																																				

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	YANGX	JINKJ	CHENHM

2025.8.4 TAG-QA-009